

## 試驗報告



報告編號：HV-22-00523

頁數：1 OF 3

報告日期：2022年02月25日

銘鋹企業有限公司

新北市中和區保健路7巷2號

產品名稱: DSB201 樓地板隔音墊

送驗廠商: 銘鋹企業有限公司

收件日期: 2022年02月09日

試驗日期: 2022年02月09日~2022年02月24日

備註: 1. 以上資料(樣品名稱、送驗人員、會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供  
2. 除非另有說明，此報告結果僅對測試之樣品負責  
未經本公司事先書面同意，此報告不可部分複製

本實驗室依據顧客所提供之試驗需求與樣品進行試驗，結果說明如下：

試驗需求：

1. 抗拉強力
2. 撕裂強度

試驗方法：請參見附頁

試驗結果：請參見附頁

註：本試驗報告抗拉強力、撕裂強度試驗委託 SGS 紡織實驗室-台北執行。

----- 1 -----

  
報告簽署人

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

## 試驗報告



報告編號：HV-22-00523

頁數：2 OF 3

報告日期：2022年02月25日

試驗方法：  
CNS 12915:2010 一般織物試驗法

試驗條件：  
抗拉強力  
試驗程序：5cm 條式法

撕裂強度  
試驗程序：梯形法

### 試驗結果：

試驗項目		試驗結果
抗拉強力(kgf)	#經向	85.3
	#緯向	117.8
撕裂強度(kgf)	#經紗	54.7
	#緯紗	83.0

註：抗拉強力測試樣品於接近夾頭處破裂。

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

## 試驗報告




報告編號：HV-22-00523

頁數：3 OF 3

報告日期：2022年02月25日

樣品照片：



試驗樣品

----- o O o -----

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.